

# WRAS<sup>®</sup>

Water Regulations Advisory Scheme

*This certifies that*  
**BUTELINE UK LTD.**

---

*has had the undermentioned product examined, tested and found, when correctly installed, to comply with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations/Scottish Water Byelaws.*

**BUTELINE RANGE OF PRESS FITTINGS FOR USE WITH BUTELINE POLYBUTYLENE BARRIER PIPE. MAXIMUM WORKING PRESSURE 16.0 BAR @ 20°C & 7.2 BAR @ 82°C.**

*This certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Directory ([www.wras.co.uk/directory](http://www.wras.co.uk/directory))*


*The product so mentioned will be listed in the Water Fittings and Materials Directory for a period until:*

**01 NOVEMBER 2016**


---

**1111074**

*Certificate No.*



*Chairman, Test and Assessment Group*



*Secretary*

**WRAS**  
**APPROVED  
PRODUCT**